

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 1450-1342:115

Page 1 of 1

CATEGORY: Expansion Joints

LISTEE: Watson Bowman Acme, 95 Pineview Drive, Amherst NY 14228
Contact: John Sobol (716) 691-7566 Fax (716) 691-9239

DESIGN: Vertical expansion/seismic joint systems: WABO SW-1200 expansion joints system with WABO SW-600 fire blanket. 10' high non-symmetrical, at least 23-5/8" of wall between joints and sides of assembly in a 10' X 10' steel stud gypsum wallboard wall. Refer to listee's data sheet and WHI Listings Book for detailed product description, assembly components and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Warnock Hersey Inc. label.

APPROVAL: Listed as a vertical expansion joint system for use in steel stud gypsum wallboard walls where 2-hour fire-rated protection is needed.

07-25-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**